

Product certificate

The company

TEUFELBESCHLAG GmbH

hereby certifies that the product

Sliding door System Variant MD Standard

has been tested on the basis of **EN 1527** by means of in-house production control and long-time testing as a heavy suspended sliding door.

The product meets the following demands:

Max. panel weight	100 kg
Glass thickness in mm	8 or 10 mm
Number of cycles	> 100 000
Functional capability	Class 6
Initial friction	Class 3

Classification key according to EN 1527:

1	2	3	4	5	6	7	8	9
-	6	2	0	-	0	-	1	3

When using Variant MD Standard a minimum panel width of 220mm has to be ensured.

Moreover, in order to guarantee for an ideal functional capability a convenient width/height ratio of the glass panels is to be favoured.

Tuerkenfeld, 01.05.2018

TEUFELBESCHLAG GmbH
Am Brand 8
82299 Tuerkenfeld
Germany